

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-1249:103 Page 1 of 1

**CATEGORY:** Control Units (Household)

**LISTEE:** CADDX-CADDI Controls, Inc, 1420 North Main Street, Gladewater, TX 75647  
Contact: \*Carol Rucker (903) 845-6941 Ext 128 Fax (903) 845-6811

**DESIGN:** Models 8600 and 8600E combination household fire and burglary alarm control unit.  
Refer to listee's printed data sheet for additional detailed product description and operational considerations. System components:

8600, 8600E	Control Unit/DACT
8601, 9050	Keypad
T-1625	Transformer

**RATING:** 120 VAC primary, 16.5 VAC secondary; 12 VDC standby

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:**

1. For household system, Fire Alarm Verification feature is NOT approve for use in California.
2. Burglary and other non-fire functions were not examined.

\*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager